

# JOHNSTON COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

205 South Second Street  
Smithfield, North Carolina 27577  
Telephone (919) 989-5180  
IMPROVEMENT PERMIT

Application No.: 58697  
Tax Map No.: \_\_\_\_\_  
Date: 4-26-02

Name: Edwards Contracting Parcel # 110K03031

Address: 158 East Dr. Wendell

Location: Echo Forest - Buffalo Rd to Wendell Rd 7-5 miles on

Right S/D Lot No.: 59

Facility: Residential LTAR: 35

Bedrooms: 3 BR Design Daily Sewage Flow: 360 Lot area: 92

New Construction:  Repair: \_\_\_\_\_ Water Supply: public

Soil/Site Classification: P. 5

Septic Tank Size: 900g Grease Trap Size: N/A

Pump Tank Size: N/A Pump(s) Size: N/A

Drainfield Type: concrete Square Feet: 1080

No. Lines: 4 Width: 3' Length: 90' Depth: 18-24"

Design/Layout by: DWZ Permit Issued By: DWZ

Inspection: Lines: \_\_\_\_\_ Septic Tank/Box: \_\_\_\_\_

Pump Tank: \_\_\_\_\_ Pump(s)/Pressure: \_\_\_\_\_

Drainage: \_\_\_\_\_ Contractor: \_\_\_\_\_


## AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION

ISSUED BY: David W. Fubler DATE ISSUED: 4-26-02

By rule this septic system requires the use of an effluent filter and a waterproof seal. A riser and septic marker may also be required.

**TO ASSURE PROPER OPERATION  
MAINTENANCE IS REQUIRED**

maintain 15' from surface of water to top drain line (marked by white flags)



NOT TO SCALE  
permit revised 4/19/05  
to show location of  
proposed pool (reinspection  
permit # 69692). DEP

Keep right edge of  
pool even with right  
edge of house, or no  
more than 1' (one foot)  
to the left of right  
edge of house.

OPERATION PERMIT BY: Causey DATE: 4/20/05

Systems shall be installed as shown in sketch or as on attached plans and specifications. Any unauthorized site disturbance, filling, soil removal, or layout changes may result in this permit being revoked. This authorization for wastewater system to construct is good for 5 years from date of issue.